

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2024/SZ/ 362

Dated: 01/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Ambience Public School**, located at **Plot No- A-1, Safdarjung Enclave, New Delhi - 110029** comprised of 2 tier Basement, Ground and Four upper floors (lower basement & caretaker room at terrace floor are sealed) owned/ occupied by **Ambience Education Society** was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/221 DL 12/03/2021. The said premises was re-inspected by officer concerned of this department on 19/03/2024 in presence of Sh. Manoj Shah of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building (**one basement, ground plus four upper floors only**) is fit for occupancy class "**Educational Building Group - B**" with effect from 01/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38, of Delhi Fire Service Rules 2010.

Issued on 01/04/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Ambience Public School, at Plot No- A-1, Safdarjung Enclave, New Delhi - 110029.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


Principal
AMBIENCE PUBLIC SCHOOL
A-1, SAFDARJUNG ENCLAVE,
NEW DELHI - 110029


Manager
AMBIENCE PUBLIC SCHOOL
A-1, S. J. Enclave,
New Delhi-110029.